

****ALL LIGHT POLE BASES ARE CUSTOM, & ARE NON-RETURNABLE****

SPECIFICATIONS :

- CONCRETE MINIMUM COMPRESSIVE STRENGTH - 4,000 PSI @ 28 DAYS.
- CONCRETE AIR ENTRAINMENT : 4% - 9%.
- TYPE I , OR TYPE III CEMENT.
- STEEL REINFORCEMENT:
 - #3 DEFORMED VERTICAL BAR (GR. 40) ASTM A-615.
 - #4 DEFORMED BAR HORIZONTAL HOOPS @ 12" O.C., (GR.60) ASTM A-615
- APPROXIMATE WEIGHT : 235 LBS/FT.
- ANCHOR BOLTS PROVIDE BY OTHERS.
- BOLT PATTERN PER LIGHT POLE MANUFACTURER SPECIFICATIONS.


Conduit Size :

Customer Acceptance (Signature) _____

Conduit Location (as Required) :
0,90,180,270 Degrees

Date _____

ENGINEERS REMARK :

NOTES :		 EASTERN PRECAST COMPANY , INCORPORATED 2 COMMERCE DRIVE, BROOKFIELD, CT 06804 PHONE : (203) 775 - 0230 FAX : (203) 740 - 2059 WWW.EASTERNPRECAST.COM	
MATERIAL :		18" CONCRETE LIGHT POLE BASE	
DOCUMENT APPROVED BY :	DATE :	MODEL NO.	LOAD RATING
	DWNG DATE : 02/12/2018	TOLERANCE	REVISION 1 - DATE
	CHKD DATE :		REVISION 2 - DATE
			REV